

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE

No- 205/जी०स्वा०आर०/न०नि०म०कृ०मथुरा/2022-23 DATE 02/05/2022

it is certified that an inspection team headed by S. S yadav  
Zonal Sanitary officer (Name of Officer with designation) from Nagari Nigam  
Mathura Vrindavan (Name of Department /Officer) Inspected Deepak Kumar  
SFI Nagari Nigam Mathura Vrindavan (Name &  
Address of the School) On 26/04/2022 and found that the M.P.S.M GRACE  
CONVENT SCHOOL MATHURA (Name of school) has safe drinking water  
facilities for the students and members of staff of the institution and is maintaining the  
hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central /State/UT Govt.

The above valid for a period of 2022-23

Signature with Seal: \_\_\_\_\_

Name

Designation

S.S. YADAV  
250  
**S.S. YADAV**  
ZONAL SANITARY OFFICER  
NAGAR NIGAM MATHURA VRINDAVAN

To

M.P.S.M GRACE  
CONVENT SCHOOL  
MATHURA

(Name & Address of the institution)

Myra Singh  
प्रधानचार्य/Principal  
एम पी एस एम ग्रेस कॉन्वेंट स्कूल  
M.P.S.M. Grace Convent School  
गनेशरा स्टेडियम के सामने, गनेशरा  
कृष्णा नगर, मथुरा

Manager  
एम.पी.एस.एम. ग्रेस कॉन्वेंट स्कूल  
M.P.S.M. Grace Convent School  
गनेशरा स्टेडियम के सामने, गनेशरा  
कृष्णा नगर, मथुरा



# UTTAR PRADESH JAL NIGAM

## WATER-TESTING LABORATORY, JAISINGH PURA, MATHURA

### PHYSICAL, CHEMICAL AND BACTERIOLOGICAL TEST - REPORT

TEST REPORT NO.: 32248

ISSUING DATE 29-04-2022

NAME OF TOWN/VILLAGE/TOWN [WITH CODE] : GANESHRA  
BLOCK /DISTRICT : MATHURA  
LOCATION/SOURCE OF SAMPLE : M.P.S.M. GRACE CONVENT SCHOOL  
LOCATION OF SOURCE : T.W  
NAME OF PERSON WHO COLLECT THE SAMPLE : RAHUL KUMAR  
DATE AND TIME OF RECEIVED SAMPLE IN LAB : 28-04-2022 (10:52AM)  
DATE OF ANALYSIS : 28-04-2022  
DATE OF START OF ANALYSIS WITH TIME : 28-0-2022 (01:15PM)

### PHYSICAL AND CHEMICAL EXAMINATION

S.NO	PARAMETER	UNIT	RESULT	ACCEPTABLE RANGE
1.	TURBIDITY	NTU	1.0	2.50 - 10
2.	ODOUR	Agreeable	LESS	LESS
3.	pH	NA	7.2	6.50 - 8.50
4.	TDS	Mg/Lit	74	500.0 - 2000.0
5.	CHLORIDE	Mg/Lit	188	200.0 - 1000.0
6.	ARSENIC	Mg/Lit	00	0.01 - 0.05
7.	FLOURIDE	Mg/Lit	0.3	1.0 - 1.5
8.	SULPHATE	Mg/Lit	-	200 - 400
9.	IRON	Mg/Lit	0.3	0.30 - 1.00
10.	NITRATE	Mg/Lit	13	45.00 - 45.00
11.	TOTAL HARDNESS	Mg/Lit	490	300.0 - 600.0
12.	RESIDUAL CHLORINE	Mg/Lit	-	0.20 - 1.00
13.	MANGANESE	Mg/Lit	-	0.05 - 0.50
14.	CONDUCTIVITY	Mg/Lit	10	250 - 1000
15.	ALKALINITY	Mg/Lit	25	200 - 800

S.LAB ASSISTANT

REMARK:

PASS  
 FAIL

*Rahul Kumar*  
Manager  
एम.पी.एस.एम. ग्रेस कॉन्वेंट स्कूल  
M.P.S.M. Grace Convent School  
गनेशरा स्थलियन के सामने, गुनेशरा  
कृष्णा नगर, मथुरा

*Manoj*  
CHEMIST/JUNIOR ENGINEER  
WATER TESTING LABORATORY  
U.P. JAL NIGAM JAISINGH PURA  
MATHURA U.P.

### DISCLAIMER:

1. THE REPORT SHALL NOT BE REPORTED EXCEPT IN FULL WITHOUT THE APPROVAL OF THE LABORATORY.
2. THE REPORT AT RESULTS APPLY ONLY TO THE SAMPLE AS RECEIVED.

*Myra Singh*  
प्रधानाधिका/Principal  
एम पी एस एम ग्रेस कॉन्वेंट स्कूल  
M.P.S.M. Grace Convent School  
गनेशरा  
कृष्णा नगर, मथुरा